



GRANITE STATE ANALYTICAL SERVICES, LLC

22 Manchester Road, Unit 2, Derry, NH 03038

Phone (800) 699-9920

(603) 432-3044

Fax (603) 434-4837

<http://www.granitestateanalytical.com/>

DRINKING WATER COMPLIANCE REPORT

DATE PRINTED: 06/08/2016 **CHEMICAL RESULTS FOR THE 2nd QUARTER 2016** **LAB ID#** 1015

SAMPLE ID#: 1606-00860-001 **DATE & TIME COLLECTED:** 06/07/2016 3:50 PM

SAMPLED BY: Mencis, Edward **DATE & TIME RECEIVED:** 06/07/2016 4:38 PM

SAMPLE CATEGORY: Routine Sample **SYSTEM EPA ID #:** 2089010

SYSTEM NAME: Sandown Town Hall Fire Station **WATER SYSTEM TYPE:** Non-Transient, Non-Community

SAMPLE AGENT #: 603-867-6085 **SYSTEM TOWN:** Sandown

RECEIPT TEMP: ON ICE 11.6 CELSIUS **SAMPLE LOCATION:** 502 Mens Room Sink /Town Hall /002

BAR CODE:

CLIENT JOB

Test Description	Results	Test Units	DQ Flag	RL	EPA Limit	Method	Analyst	Date & Time Analyzed
Nitrate as N*	<0.2	mg/L		0.2	10 mg/L	EPA 300.0	ST-NH	06/08/16 3:52 AM

The results presented in this report relate to the samples listed above in the condition in which they were received.
 RL: "Reporting limit" means the lowest level of an analyte that can be accurately recovered from the matrix of interest.

Data Qualifier (DQ) Flags: None

* NELAC Accredited Analysis



Donald J. D'Anjou, Ph. D.
Laboratory Director

This analysis meets NELAC requirements except as noted.

State Certifications: | NH 1015 | MA M-NH003 | ME NH00003 | RI 101513 | VT VT-101507 |

This certificate shall not be reproduced, except in full, without the written approval of Granite State Analytical Services, LLC