



GRANITE STATE ANALYTICAL SERVICES, LLC

22 Manchester Road, Unit 2, Derry, NH 03038

Phone (800) 699-9920

(603) 432-3044

Fax (603) 434-4837

<http://www.granitestateanalytical.com/>

CERTIFICATE OF ANALYSIS FOR DRINKING WATER

DATE PRINTED: 05/20/2016
CLIENT NAME: Town of Sandown Rec Dept.
CLIENT ADDRESS: PO Box 642, Attn:Recreation Dept.
Sandown, NH 03873

Legend

- Passes ✓
- Fails EPA Primary ⊗
- Fails EPA Secondary ▽
- Fails EPA Proposed Limit ✕

SAMPLE ID#: 1605-02326-001
SAMPLED BY: Client-Customer

DATE AND TIME COLLECTED: 05/19/2016 3:20 PM

DATE AND TIME RECEIVED: 05/19/2016 3:59 PM

ANALYSIS PACKAGE: Bac P/A

SAMPLE ADDRESS: Sandown Miller Field
Sandown NH

RECEIPT TEMPERATURE: 9.1 CELSIUS

CLIENT JOB #

LOCATION:

Test Description	Results	Test Units	Pass /Fail	DQ Flag	RL	EPA Limit	Method	Analyst	Date-Time Analyzed
Coliform Bacteria*	Absent	P-A/100mL			Absent	No Limit	SM 9223B	ST-NH	05/19/16 4:15 PM
E. coli Bacteria*	Absent	P-A/100mL	✓		Absent	Absent	SM 9223B	ST-NH	05/19/16 4:15 PM

The results presented in this report relate to the samples listed above in the condition in which they were received.
RL: "Reporting limit" means the lowest level of an analyte that can be accurately recovered from the matrix of interest.

Data Qualifier (DQ) Flags: None

* NELAC Accredited Analysis



Donald J. D'Anjou, Ph. D.
Laboratory Director

This analysis meets NELAC requirements except as noted.

State Certifications: | NH 1015 | MA M-NH003 | ME NH00003 | RI 101513 | VT VT-101507 |

This certificate shall not be reproduced, except in full, without the written approval of Granite State Analytical Services, LLC